

## State Water Resources Control Board

June 7, 2016

(Via email and Certified Mail)

**CERTIFIED MAIL**

**NO. 7015 1520 0001 8019 6521**

Mr. Rick Mathews  
Fleet Maintenance Coordinator  
City of Anderson  
1887 Howard Street  
Anderson, California 96007  
[rmathews@ci.anderson.ca.us](mailto:rmathews@ci.anderson.ca.us)

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS  
LOCATED AT THE CITY OF ANDERSON CORP YARD, 2450 BARNEY ROAD,  
ANDERSON**

Dear Mr. Mathews:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on May 25, 2016, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and title 23, California Code of Regulations (CCR), chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	<b>Failure to Monitor Product Piping</b> – The piping sump sensors are not able to detect a leak at the earliest possible opportunity because the test boots had not been removed.	Diesel, UL 4000	May 25, 2016	Ongoing	23 CCR 2630(d)
2	<b>Failure to Maintain Monitoring Records On-Site</b> – The 2013 monitoring certification records were not available at the time of the inspection.	All	May 25, 2016	Ongoing	23 CCR 2712(b)
3	<b>Failure to Maintain Financial Responsibility</b> – The financial responsibility certification form was not available at the time of inspection.	All	May 25, 2016	Ongoing	H&SC 25292.2; 23 CCR 2711(a)(11)

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	<b>Failure to Tag Monitoring Equipment</b> – Annual testing tags were not observed on the tank annular sensors or the monitoring panel.	All	May 25, 2016	Ongoing	23 CCR 2638(f)

**You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Shasta County Environmental Health Division within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.**

Please send all compliance documentation to the following:

**State Water Board**

Mr. Thomas Henderson  
UST Enforcement Unit  
Office of Enforcement  
State Water Resources Control Board  
1001 I Street, 16<sup>th</sup> Floor  
Sacramento, California 95814  
[tom.henderson@waterboards.ca.gov](mailto:tom.henderson@waterboards.ca.gov)

**Local CUPA**

Mr. Kevin Westlake  
Environmental Health Specialist  
Shasta County Environmental Health Division  
1855 Placer Street, Suite 201  
Redding California, 96001  
[kwestlake@co.shasta.ca.us](mailto:kwestlake@co.shasta.ca.us)

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at [amantha.henkel@waterboards.ca.gov](mailto:amantha.henkel@waterboards.ca.gov).

Sincerely,



Amantha Henkel  
Senior Environmental Scientist  
UST Enforcement Unit  
**Office of Enforcement**

cc: see next page

cc: *(via email only)*

Mr. Kevin Westlake  
Shasta County Environmental Health  
[kwestlake@co.shasta.ca.us](mailto:kwestlake@co.shasta.ca.us)

Mr. Michael Jensen  
City of Anderson  
[mjensen@ci.anderson.ca.us](mailto:mjensen@ci.anderson.ca.us)

Mr. David Durrett  
City of Anderson  
[ddurette@ci.anderson.ca.us](mailto:ddurette@ci.anderson.ca.us)